

NESCOFI@BTF closure & NEURAPID start up meeting

INFN-LNF, 26 February 2014

Aula conversi

Neutron Facility @ PoliMi

Numerical study with the FLUKA Monte Carlo code: results




POLITECNICO
DI MILANO

Scientific Aim:


to develop a neutron facility capable of providing radiation fields accurately characterized, a facility adequately equipped in order to host all kind of neutron detectors and measurements.

Numerical study with the FLUKA Monte Carlo code





FLUKA simulations: settings





- Source: AmBe spectrum (ISO/DIS 8529-1); cylindrical isotropic source - right cylinder ($\Phi=1$ mm).
- Scoring: neutron and photon fluence with the card USRTRACK, a "track-length estimator" which estimate the fluence by the ratio between the mean value of the track lengths within the reference volume and the volume itself ($\text{cm}/\text{cm}^3 \Rightarrow \text{cm}^{-2}$).
Results of USRTRACK are expressed in terms of part/cm²/GeV/primary.
- Reference volume: void spheres with $R=0.25$ cm, $R=0.5$ cm and $R=1$ cm
- Number of spheres: 15, 8 and 5 (for $R=0.25$ cm, $R=0.5$ cm e $R=1$ cm, respectively) along the radius of the cylindrical structure, inside the “measurement volume” at 5 cm from the Pb plate.




Comparison between results obtained by simulating a “point” source and by simulating a source with effective dimensions (cylinder, $\Phi=1.9$ cm $h=5$ cm)





Spheres with different dimensions: statistics




Results for $R_{\text{sph}}=1 \text{ cm}$





Mean ratio thermal/total = 84.3%








Neutron dose rate in terms of H*(10)





Mean dose rate: $52 \mu\text{Sv h}^{-1}$

<i>pos(cm)</i>	<i>total dose rate</i>	<i>thermal dose rate</i>	<i>fast dose rate</i>
0	$41.65 \pm 22\%$	$15.68 \pm 2\%$	$26.03 \pm 34\%$
3	$45.57 \pm 23\%$	$15.87 \pm 2\%$	$29.75 \pm 34\%$
6	$52.3 \pm 22\%$	$16.12 \pm 3\%$	$36.24 \pm 30\%$
9	$59.12 \pm 22\%$	$16.69 \pm 2\%$	$42.5 \pm 29\%$
12	$63.58 \pm 21\%$	$16.66 \pm 2\%$	$46.99 \pm 28\%$

Gamma fluence rate



Gamma dose rate




pos(cm)	gamma dose rate
0	1.4 ±23%
3	1.5 ±24%
6	1.5 ±24%
9	1.5 ±23%
12	1.6 ±22%

Mean dose rate: 1.5 $\mu\text{Sv h}^{-1}$





Dose rate outside the facility




dose rate N ($\mu\text{Sv/h}$)	distance	
	10 cm	100 cm
bottom	$257.6 \pm 11\%$	$10.5 \pm 52\%$
source	$90.9 \pm 19\%$	$5.7 \pm 62\%$
meas.volume	$7.9 \pm 54\%$	$5.7 \pm 58\%$
top	$1.5 \pm 85\%$	$0.2 \pm 99\%$
dose rate G ($\mu\text{Sv/h}$)		
bottom	$5.2 \pm 16\%$	$0.22 \pm 35\%$
source	$2.6 \pm 21\%$	$0.18 \pm 39\%$
meas.volume	$0.96 \pm 32\%$	$0.19 \pm 34\%$
top	$0.33 \pm 38\%$	$1.5 \pm 99\%$

Top h=5 cm instead of 10 cm




	Top h=10 cm		Top h=5 cm	
	distance	distance	distance	distance
dose rate N ($\mu\text{Sv/h}$)	10 cm	100 cm	10 cm	100 cm
bottom	$257.6 \pm 11\%$	$10.5 \pm 52\%$	$242.7 \pm 11\%$	$10.1 \pm 51\%$
source	$90.9 \pm 19\%$	$5.7 \pm 62\%$	$88.4 \pm 17\%$	$5.3 \pm 58\%$
meas.volume	$7.9 \pm 54\%$	$5.7 \pm 58\%$	$7.1 \pm 57\%$	$4.8 \pm 62\%$
top	$1.5 \pm 85\%$	$0.2 \pm 99\%$	$2.9 \pm 66\%$	$0.3 \pm 99\%$
dose rate G ($\mu\text{Sv/h}$)				
bottom	$5.2 \pm 16\%$	$0.22 \pm 35\%$	$5.3 \pm 14\%$	$0.22 \pm 38\%$
source	$2.6 \pm 21\%$	$0.18 \pm 39\%$	$2.6 \pm 19\%$	$0.17 \pm 39\%$
meas.volume	$0.96 \pm 32\%$	$0.19 \pm 34\%$	$0.97 \pm 28\%$	$0.18 \pm 45\%$
top	$0.33 \pm 38\%$	$1.5 \pm 99\%$	$0.5 \pm 29\%$	$0.4 \pm 40\%$

Design of the facility



Block 3



source